



Enviolyte Water Disinfection System

Client: REHABILITATION GERIATRIC
CLINIC KOS Group

City: Milan

Country: Italy

mail: www.kosgroup.cpm

Unit: ELA 200anw installed on April
18th, 2019

Serial nr. 190301

Purpose: Legionella control.

Previous system: overheating



Main Water plus hot water, total 50 cm/day

Dosing: proportional plus Redox Dosage hot water.

Setting: 2.5 ppm chlorine, and 700mV on hot water

Special: Redox probe



Unit ELA200 anw



Dosing station with proportional and Redox pump

Acqua
Attiva
Tecnologia dell'Acqua